

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 2280-1647:101

Page 1 of 1

CATEGORY: Interior Coating Materials (Flame Spread)

LISTEE: Contego International, Inc, 334 Greyhound Pass West, Carmel, IN 46032
Contact: Tony Scott (317) 580-0665 FAX (317) 580-0663

DESIGN: Contego Intumescent Paint water soluble interior coating material. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:		Oriented Strand Board (OSB)	Louisiana-Pacific PMDO (Primed Medium Density Overlay) on OSB
	Flame Spread:	10	10
	Smoke Developed:	10	25
	Application Rate per coat:	60 sq. ft per gallon	60 sq. ft. per gallon

Uniform Building Code (UBC) Standard 26-2 Thermal Barrier Test - Rating of 23 minutes

UBC Standard 26-3 Room Fire Test for Interior Foam Plastic Systems – Met all criteria of the test procedure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as Class I coating material when used on wood of interior wall/ceiling surfaces to reduce flame spread when the coatings are applied at 60 sq. ft. per gallon. Also listed as a Thermal Barrier per UBC Section 2602.4 and for specific approval per UBC Section 2602.6. Refer to listee's Instruction Manual for details.

1-10-2006 jew



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 28, 2006**

Listing Expires June 30, 2007

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager